

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14, 21047 Saronno (VA), Italy

Name and address of the manufacturer

TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14, 21047 Saronno (VA), Italy

Name and address of the factory

TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14, 21047 Saronno (VA), Italy*When more than one factory*☒ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings:

Test class II / Type 2 & Test class III / Type 3

Uc: 320 V~, In: 5 kA, I_{max}: 10 kA, Uoc: 12 kV, Up: 1,5 kV

Iscrr: 300 A, II: 3 A, IP20

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SPD GM CLII

Additional information

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6072097.50, 6148827.50 and 6221038.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-06-13

Signature: Carol Jwo



Ref. Certif. No.

NL-117383

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Intelligent Components Technology Zhuhai Ltd
No.912, Dexiang Road, Pingsha Town, Zhuhai City, 519005 Guangdong, China

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands



Date: 2025-06-13

Signature: Carol Jwo