

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

TCI Telecomunicazioni Italia Srl
Via Parma 14, 21047 Saronno (VA),
Italy

Name and address of the manufacturer

TCI Telecomunicazioni Italia Srl
Via Parma 14, 21047 Saronno (VA),
Italy

Name and address of the factory

TCI Telecomunicazioni Italia Srl
Via Parma 14, 21047 Saronno (VA),
Italy*Note: When more than one factory, please report on page 2*☐ Additional information on page 2

Ratings and principal characteristics

Test class II / Type 2 & Test class III / Type 3
Uc: 320 V~, In: 5 kA, I_{max}: 10 kA, Uoc: 12 kV
Up: 1,5 kV (L-N), 2,0 kV (L-PE), Isccr: 300 A, IL: 3 A, IP20

Trademark / Brand (if any)



TCI

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SPD MM CLI, SPD MM CLII

Additional information (if necessary may also be reported on page 2)

This certificate replaces NL-79705 dated on 2022-03-22 due to adding the alternative Terminal model.

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

National differences:

EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6120985.50 and 6148247.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2023-02-24

Signature: Kate Xu