

CERTIFICATE

Issued to:
Applicant:
TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14
21047 Saronno (VA), Italy

Licensee:
TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14
21047 Saronno (VA), Italy

Product : LED driver
Trade name(s) : TCI LED
Type(s)/model(s) : DC MAXI JOLLY SLIM NFC DALI TW 50

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN IEC 62384:2020 and EN 61347-2-13:2014/A1:2017
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2033015

DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 15 November 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-132624

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED driver
Trade name(s)	: TCI LED
Type(s)/model(s)	: DC MAXI JOLLY SLIM NFC DALI TW 50
Input current	: 0,23-0,26
Rated voltage	: 220-240 VAC/VDC
Power factor	: 0,98 (Pout \geq 40W)
Rated wattage	: 5-50,4 W
Rated frequency	: 50-60 Hz
Ambient temperature	: -25- 45 °C
Max. case temperature	: 75 °C
Additional information	: built-in controlgear with double or reinforced insulation without cable clamps, independent control gear with cable clamps, SELV, 120 °C thermal protection, non-inherently short circuit proof;

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN IEC 62384:2020
EN 61347-2-13:2014/A1:2017

Test result

The test results are laid down in DEKRA test file 490729900.

Additional information

The list of components is laid down in test report 4907299.50, 4907299.51.

Conclusion

The examination proved that all requirements were met.

Factory location

Helvar Oy Ab
Yrittajantie 23
03600 Karkkila, Finland

Trade name(s) : TCI LED stands for

