

CERTIFICATE

Issued to:
Applicant:
TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14
21047 Saronno (VA), Italy

Licensee:
TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14
21047 Saronno (VA), Italy

Product : Electronic controlgear (LED driver)
Trade name(s) : TCI LED
Type(s)/model(s) : DC MAXI JOLLY SLIM NFC DALI TW 100

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2033015


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 1 November 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-131986

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K. Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Electronic controlgear (LED driver)
Trade name(s)	: TCI LED
Type(s)/model(s)	: DC MAXI JOLLY SLIM NFC DALI TW 100
Rated voltage	: 220-240 Vac/Vdc
Rated frequency	: 50-60 Hz
Urated	: 45-230 Vdc
Ambient temperature	: -25 - +50 °C
Max. case temperature	: 88 °C
Rated wattage	: 23-100 W
Additional information	: Built-in, auto-wound, 120 °C thermal protection, class I, non-inherently short-circuit proof, EL mark.

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN IEC 62384:2020

Test result

The test results are laid down in DEKRA test file 490730100.

Additional information

The list of components is laid down in test report 4907301.50, 4907301.51.

Conclusion

The examination proved that all requirements were met.

Factory location

Helvar Oy Ab
Yrittäjäntie 23
03600 Karkkila, Finland

Trade name(s) : TCI LED stands for

