

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Independent controlgear for supplying LED modules

Name and address of the applicant

Oy Lival Ab
Lukkarinmäentie 1
FI-04130, Sipoo, Finland

Name and address of the manufacturer

Oy Lival Ab
Lukkarinmäentie 1
FI-04130, Sipoo, Finland

Name and address of the factory

See page 2

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

PRI: 220-240 Vac; 50/60 Hz; I_{max} 0,16 A; PF 0,85 – 0,95

SEC: 200-750 mA; 5-40 Vdc; 30 W Max; Vomax 59 Vdc; Ta 0...35 °C; Tc max 74 °C; SELV; class II; IP20

Trademark / Brand (if any)

GLOBAL trac®

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

GA017-Super

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-2-13:2014
IEC 61347-2-13:2014/AMD1:2016
IEC 61347-1:2015
IEC 61347-1:2015/AMD1:2017
IEC 62384:2020

National Differences:

-

As shown in the Test Report Ref. No. which forms part of this Certificate

HELES2208000948-1, HELES2208000948-2

This CB Test Certificate is issued by the National Certification Body

SGS Fimko Ltd
Takomotie 8
FI-00380 Helsinki, Finland

Date: 2023-11-29

Signature:


Joonas Leinonen
Certification Manager

Name and address of the factories:

1. Eino Korhonen Oy
Teollisuustie 25
FI-06150, Porvoo, Finland

2. OÜ EKOY Elektroonika
Ekoi kinnistu, Altküla
Lääne-Harju vald,
EE-76012, Harjumaa, Estonia

Additional information:

Compatible with track systems Global Trac Pro and Global Trac PULSE by Nordic Aluminium.

Requirements for independent controlgears has been checked according to IEC 60570:2003 +AMD1:2017 + AMD2:2019 & IEC 60598-1:2020.

SGS Fimko Ltd
Takomotie 8
FI-00380 Helsinki, Finland



Date: 2023-11-29

Signature:


Joonas Leinonen
Certification Manager