

CERTIFICATE

Issued to:
Applicant:
TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14
21047 Saronno (VA), Italy

Licensee:
TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14
21047 Saronno (VA), Italy

Product : Surge Protective Devices
Trade name(s) : TCI
Type(s)/model(s) : SPD MM/400

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to EN 61643-11:2012 and EN 61643-11:2012/A11:2018
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6064204


DEKRA hereby grants the right to use the DEKRA Mark.

The DEKRA Mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Mark certification agreement.


This certificate is issued on 8 May 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-140367

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



31-140367

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Surge Protective Devices
Trade name(s)	: TCI
Type(s)/model(s)	: SPD MM/400
Number of port(s)	: One
SPD type (Test class)	: Type 2 (II) & Type 3 (III)
Maximum continuous operating voltage (Uc)	: 270 V~
Nominal discharge current (In 8/20µs)	: 5 kA
Maximum discharge current (Imax 8/20µs)	: 10 kA
Open circuit voltage for Type 3 (III) (Uoc)	: 12 kV
Voltage protection level (Up)	: 1.8 kV
Rated load current (Il)	: 5 A
Short-circuit current rating (Iscrr)	: 300 A
Modes of protection	: L-N
Connection	: 1.0 to 1.5 mm ²
Degree of protection	: IP20

TESTS**Test requirements**

EN 61643-11:2012

EN 61643-11:2012/A11:2018

Test result

The test results are laid down in DEKRA test file 617509200.

Additional information

The list of components is laid down in test report 6175092.50.

Conclusion


The examination proved that all requirements were met.

Factory location

TCI Telecomunicazioni Italia S.r.l.

Via Parma, 14

21047 Saronno (VA), Italy

Trade name(s): TCI stands for The logo for TCI, consisting of a stylized, grey, textured horse head profile facing right, followed by the letters "TCI" in a bold, black, sans-serif font.