

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Surge Protective Devices

Name and address of the applicant

TCI Telecomunicazioni Italia S.r.l.  
Via Parma, 14, 21047 Saronno (VA), Italy

Name and address of the manufacturer

TCI Telecomunicazioni Italia S.r.l.  
Via Parma, 14, 21047 Saronno (VA), Italy

Name and address of the factory

TCI Telecomunicazioni Italia S.r.l.  
Via Parma, 14, 21047 Saronno (VA), Italy*When more than one factory* Additional information on page 2

Ratings and principal characteristics

**Product data**

Ratings:

Test class II / Type 2 & Test class III / Type 3, Uc: 270 V~, In: 5 kA, Imax:  
10 kA, Uoc: 12 kV, Up: 1.8 kV, Isccr: 300 A, IP20

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SPD MM/400

Additional information

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

**National differences:**  
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

6175092.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands

Date: 9 May 2024

Signature: May Liu