

CERTIFICATE

Issued to:
Applicant:
TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14
21047 Saronno (VA), Italy

Licensee:
TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14
21047 Saronno (VA), Italy

Product : Electronic controlgear for LED modules
Trade name(s) : TCI
Type(s)/model(s) : SIRIO SQ 110W/200-700 1-10V, SIRIO SQ 110W/300-1000 1-10V,
SIRIO SQ 75W/200-700 1-10V, SIRIO SQ 75W/300-1000 1-10V and
SIRIO SQ 75W/500-1500 1-10V

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 61347-1:2015, EN 61347-1:2015/A1:2021, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2033015


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 7 July 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-126260 REV.3

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Kreny Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Electronic controlgear for LED modules
Trade name(s)	: TCI
Type(s)/model(s)	: SIRIO SQ 110W/200-700 1-10V, SIRIO SQ 110W/300-1000 1-10V, SIRIO SQ 75W/200-700 1-10V, SIRIO SQ 75W/300-1000 1-10V and SIRIO SQ 75W/500-1500 1-10V
Rated voltage	: 220-240 Vac
Rated frequency	: 50/60 Hz
Power factor	: 0,95
Ambient temperature (ta)	: -40...+55 °C
Description	: Built-in LED driver with double insulation

Product data – type SIRIO SQ 110W/200-700 1-10V

Rated input current	: 0,49-0,59A
Rated input power	: 121 W
Output current	: 0,2-0,7A
Output voltage	: 70-220 Vdc
Uout	: 300 Vmax
Output power	: 110 W
Case temperature (tc)	: 90 °C

Product data – type SIRIO SQ 110W/300-1000 1-10V

Rated input current	: 0,49-0,59A
Rated input power	: 121 W
Output current	: 0,3-1,05A
Output voltage	: 50-160 Vdc
Uout	: 230 V
Output power	: 110 W
Case temperature (tc)	: 90 °C

Product data – type SIRIO SQ 75W/200-700 1-10V

Rated input current	: 0,34-0,4A
Rated input power	: 84 W
Output current	: 0,2-0,7A
Output voltage	: 50-150 Vdc
Uout	: 220 V
Output power	: 75 W
Case temperature (tc)	: 80 °C

Product data – type SIRIO SQ 75W/300-1000 1-10V

Rated input current	: 0,34-0,4A
Rated input power	: 84 W
Output current	: 0,3-1,05A
Output voltage	: 35-108 Vdc
Uout	: 150 V
Output power	: 75 W
Case temperature (tc)	: 80 °C

Product data – type SIRIO SQ 75W/500-1500 1-10V

Rated input current	: 0,34-0,4A
Rated input power	: 84 W
Output current	: 0,5-1,5A
Output voltage	: 25-75 Vdc
Uout	: 120 V;SELV
Output power	: 75 W
Case temperature (tc)	: 80 °C

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN IEC 62384:2020

Test result

The test results are documented in DEKRA test file 622861900.

Additional information

For component list refers to annex 1 of test reports 6228619.50/52.

This certificate replaces certificate No. 31-126260 REV.2 which we hereby declare invalid.

The list of components is laid down in test report 6228619.50 and 6228619.52.

Conclusion

The examination has confirmed that all requirements were met.

Factory locations

The factory locations are registered with the numbers 674666, 306303 and 1845.