

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14, 21047 Saronno (VA), Italy

Name and address of the manufacturer

TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14, 21047 Saronno (VA), Italy

Name and address of the factory

TCI Telecomunicazioni Italia S.r.l.
Via Parma, 14, 21047 Saronno (VA), Italy

When more than one factory

 Additional information on page 2

Ratings and principal characteristics

Product data

Ratings:

Test class II / Type 2 & Test class III / Type 3 Uc: 320 V~, In: 10 kA, Imax: 20 kA; Uoc: 20 kV Up: 1.7 kV (L-N), 2.8 kV (L-PE), Isccr: 300 A, IL: 5 A, IP20



Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

SPD MM CLI 230/20K

Model / Type Ref.

 Additional information on page 2

Additional information

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

National differences:
EU Group Differences

6229051.50

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-01-19


Signature: Kate Xu