

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Electronic emergency units for LED lighting (self-contained)
Name and address of the applicant	TCI Telecomunicazioni Italia S.r.l. Via Parma, 14, 21047 Saronno (VA), Italy
Name and address of the manufacturer	TCI Telecomunicazioni Italia S.r.l. Via Parma, 14, 21047 Saronno (VA), Italy
Name and address of the factory	TCI Telecomunicazioni Italia S.r.l. Via Parma, 14, 21047 Saronno (VA), Italy
<i>When more than one factory</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	Product data Ratings: Rated voltage : 220-240 V Rated frequency : 50...60 Hz Ambient temperature range : ta = +5 °C...+50 °C Rated duration for emergency operation : 1h / 3h Batteries : LiFePO4
Trademark / Brand (if any)	TCI
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	ILED-A 3W 12-55V 1H, ILED-A 3W 12-55V 3H, ILED-A 3W 30-220V 1H, ILED-A 3W 30-220V 3H, ILED-DALI 3W 12-55V 1H, ILED-DALI 3W 12-55V 3H, ILED-DALI 3W 30-220V 1H, ILED-DALI 3W 30-220V 3H, ILED 3W 12-55V 1H, ILED 3W 12-55V 3H, ILED 3W 55-220V 1H and ILED 3W 55-220V 3H
Additional information	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-2-7:2011, IEC 61347-2-7:2011/AMD1:2017, IEC 61347-2-7:2011/AMD2:2021, IEC 61347-1:2015 and IEC 61347-1:2015/AMD1:2017 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	3439908.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-04-24

Signature: Kreny Lin