



中国国家强制性产品认证证书

证书编号: 2023181002043551

发证日期: 2023 年 06 月 27 日

有效期至: 2028 年 06 月 26 日

认证委托人名称
及注册地址 TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) 意大利

生产者 (制造商)
名称及注册地址 TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) 意大利

生产企业名称
及生产地址 TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) 意大利

产品名称和系列、
型号、规格 LED 模块用交流电子控制装置 (LED 控制装置, 独立式, 恒流模式, 安全特低
电压, II 类, IP20, 适宜直接安装在普通可燃材料表面)
见附件, 110-240V ~ 50/60Hz

产品标准和
技术要求 GB/T 17743-2021, GB 17625.1-2022, GB 19510.1-2009, GB 19510.14-2009

上述产品符合强制性产品认证实施规则 CNCA-C10-01: 2014 的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C146-P

本证书的相关信息可通过认监委网站 www.cnca.gov.cn 或扫描左下方二维码查询。



邓俊尧

威凯认证检测有限公司



中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722

070371



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2023181002043551

DATE OF ISSUE: Jun. 27, 2023

DATE OF EXPIRY: Jun. 26, 2028

NAME AND REGISTERED ADDRESS OF THE APPLICANT	TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno(VA) Italy
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno(VA) Italy
NAME AND ADDRESS OF THE FACTORY	TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno(VA) Italy
NAME, MODEL AND SPECIFICATION	A. C. Supplied Electronic Controlgear For LED Modules (Independent Constant Current SELV, Class II,IP20, Suitable For Normally Flammable Surfaces) See Appendix.110-240V~ 50/60Hz
STANDARDS AND TECHNICAL REQUIREMENTS	GB/T 17743-2021,GB 17625.1-2022, GB 19510.1-2009,GB 19510.14-2009

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C10-01: 2014).

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C146-P

This certificate can be verified through CNCA's website: www.cnca.gov.cn or the QR code at the lower left.



CVC Certification & Testing Co., Ltd.

No.3, Tiantaiyi Road, High-tech Industrial Development Zone, Science City, Guangzhou (510663) P. R. China

<http://www.cvc.org.cn>

Tel: +86-20-32293722

070371



中国国家强制性产品认证证书

附录:

第 1 页 共 4 页

证书编号: 2023181002043551

纸号: 070371

序号	产品型号	参数
1	DC MINI JOLLY cod. 151400	输出: Max. 59Vdc, 250-900mA (恒流可调, 通过拨码开关调节), 调光信号: ADIM, PUSH L 调光范围: 0/1-100% 配套光源: Max. 20W LED 模块, $t_a = -25 \sim 50^{\circ}\text{C}$, $t_c = 80^{\circ}\text{C}$ (当输出功率 $\leq 16\text{W}$ 时 $t_c = 75^{\circ}\text{C}$), 
2	DC MINI JOLLY LC cod. 151401	输出: Max. 59Vdc, 100-380mA (恒流可调, 通过拨码开关调节), 调光信号: ADIM, PUSH L 调光范围: 0/1-100% 配套光源: Max. 20W LED 模块, $t_a = -25 \sim 50^{\circ}\text{C}$, $t_c = 75^{\circ}\text{C}$, 
3	DC MINI JOLLY DALI cod. 151403	输出: Max. 59Vdc, 250-700mA (恒流可调, 通过拨码开关调节), 调光信号: DALI 调光范围: 0/0.5/1-100% 配套光源: Max. 20W LED 模块, $t_a = -25 \sim 45^{\circ}\text{C}$, $t_c = 75^{\circ}\text{C}$, 
输入: 110-240V~, 50/60Hz, SELV,  , II 类, 独立式		

注: 此附录与证书同时使用时有效。

邓俊尧

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722





中国国家强制性产品认证证书

附录:

第 2 页 共 4 页

证书编号: 2023181002043551

纸号: 070371

注: DC MINI JOLLY cod. 151400拨码开关

输出功率	输出电流	拨码开关位置			
		1	2	3	4
13W	250mA	-	-	-	-
16W	300mA	-	-	-	ON
18W	350mA	-	-	ON	-
20W	400mA	-	-	ON	ON
20W	450mA	-	ON	-	-
20W	500mA	-	ON	-	ON
20W	550mA	-	ON	ON	-
20W	600mA	-	ON	ON	ON
20W	650mA	ON	-	ON	-
20W	700mA	ON	-	ON	ON
20W	750mA	ON	ON	-	-
20W	800mA	ON	ON	-	ON
20W	850mA	ON	ON	ON	-
20W	900mA	ON	ON	ON	ON

注: 此附录与证书同时使用时有效。

邓俊尧

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722





中国国家强制性产品认证证书

附录:

第 3 页 共 4 页

证书编号: 2023181002043551

纸号: 070371

注: DC MINI JOLLY LC cod. 151401 拨码开关

输出功率	输出电流	拨码开关位置			
		1	2	3	4
5.4W	100mA	-	-	-	-
6.4W	120mA	-	-	-	ON
7.5W	140mA	-	-	ON	-
8.5W	160mA	-	-	ON	ON
9.5W	180mA	-	ON	-	-
10.6W	200mA	-	ON	-	ON
12W	220mA	-	ON	ON	-
12.5W	240mA	ON	-	-	-
14W	260mA	ON	-	-	ON
15W	280mA	ON	-	ON	-
16W	300mA	ON	-	ON	ON
17W	320mA	ON	ON	-	-
18W	340mA	ON	ON	-	ON
19W	360mA	ON	ON	ON	-
20W	380mA	ON	ON	ON	ON

注: 此附录与证书同时使用时有效。

邓俊尧

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722





中国国家强制性产品认证证书

附录:

第 4 页 共 4 页

证书编号: 2023181002043551

纸号: 070371

注: DC MINI JOLLY DALI cod. 151403 拨码开关

输出功率	输出电流	拨码开关位置			
		1	2	3	4
12W	250mA	-	-	-	-
17W	350mA	-	-	-	ON
19W	400mA	-	-	ON	-
20W	450mA	-	ON	-	-
20W	500mA	-	-	ON	ON
20W	550mA	-	ON	-	ON
20W	600mA	-	ON	ON	-
20W	700mA	-	ON	ON	ON

注: 1. 铭牌上 110*-127*V~、110-120V~, 特指 UL 认证出口适用的输入。176-276Vdc、170-280Vdc 指应急照明。

2. PUSH L 调光: 通过将一个开关连接在 L 与 PUSH L 之间, 短按控制通/断; 长按开关调节输出电流的大小, 调节输出电流范围为 0/9-900mA (DC MINIJOLLY cod. 151400)、0/3.8-380mA (DC MINIJOLLY LC cod. 151401)。

注: 此附录与证书同时使用时有效。

邓俊尧

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722

