



# 中国国家强制性产品认证证书

证书编号: 2023181002043629

发证日期: 2023年06月28日

有效期至: 2028年06月27日

认证委托人名称及注册地址 TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) 意大利

生产者(制造商)名称及注册地址 TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) 意大利

生产企业名称及生产地址 TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) 意大利

产品名称和系列、型号、规格 LED 模块用直流或交流电子控制装置(LED控制装置, 独立式, 恒流模式, 安全特低电压,tc: 85°C II类, IP20, 适宜直接安装在普通可燃材料表面)  
见附件, 220-240V 0/50/60Hz

产品标准和技术要求 GB/T 17743-2021,GB 17625.1-2022,GB 19510.1-2009,GB 19510.14-2009

上述产品符合强制性产品认证实施规则 CNCA-C10-01: 2014 的要求, 特发此证。  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。  
经中国合格评定国家认可委员会认可 CNAS C146-P

本证书的相关信息可通过认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 或扫描左下方二维码查询。



邓俊逸

威凯认证检测有限公司



中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722

070532



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2023181002043629

DATE OF ISSUE: Jun. 28, 2023

DATE OF EXPIRY: Jun. 27, 2028

<b>NAME AND REGISTERED ADDRESS OF THE APPLICANT</b>	TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno(VA) Italy
<b>NAME AND REGISTERED ADDRESS OF THE MANUFACTURER</b>	TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno(VA) Italy
<b>NAME AND ADDRESS OF THE FACTORY</b>	TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno(VA) Italy
<b>NAME, MODEL AND SPECIFICATION</b>	D. C. or A. C. Supplied Electronic Controlgear For LED Modules ( Independent Constant Current SELV, tc: 85°C Class II,IP20, Suitable For Normally Flammable Surfaces) See Appendix.220-240V 0/50/60Hz
<b>STANDARDS AND TECHNICAL REQUIREMENTS</b>	GB/T 17743-2021,GB 17625.1-2022, GB 19510.1-2009,GB 19510.14-2009

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C10-01: 2014).

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C146-P

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn) or the QR code at the lower left.



*Dy Junyong*



**CVC Certification & Testing Co., Ltd.**

No.3, Tiantaiyi Road, High-tech Industrial Development Zone, Science City, Guangzhou (510663) P. R. China

<http://www.cvc.org.cn>

Tel: +86-20-32293722

070532



# 中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2023181002043629

纸号: 070532

序号	产品型号	参数
1	MP 50 K3	输出: 恒流 Max. 90Vdc, 350/500/550/650/700/750/850/900/1050mA (恒流可调, 通过拨码开关调节), 配套光源: Max. 50W LED 模块, $\nabla_{110}$ , $t_a: 45/50/55^\circ\text{C}$ (仅当输出为 700mA, Max. 40W 时, $t_a=55$ ; 输出电流为 850mA、900mA、1050mA 时, $t_a=45^\circ\text{C}$ , 其他输出状态下 $t_a=50^\circ\text{C}$ )
2	MP 50 TCM	输出: 恒流 Max. 90Vdc, 350/500/550/650/700/750/850/900/1050mA (恒流可调, 通过拨码开关调节), 配套光源: Max. 50W LED 模块, $\nabla_{130}$ , $t_a: 45/50^\circ\text{C}$ (仅当输出电流为 850mA、900mA、1050mA 时, $t_a=45^\circ\text{C}$ , 其他输出状态下 $t_a=50^\circ\text{C}$ )
输入: 220-240V, 0/50/60Hz, $t_c: 85^\circ\text{C}$ , SELV,  , II类, 独立式		

注: 此附录与证书同时使用时有效。

威凯认证检测有限公司



中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722



# 中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2023181002043629

纸号: 070532

型号: MP 50 K3 拨码开关

输出功率	ta max	输出电流 /电压	拨码开关位置					
			6	5	4	3	2	1
25W	50°C	350mA	-	-	-	-	-	-
35W	50°C	500mA	ON	-	-	-	-	-
39W	50°C	550mA	-	ON	-	-	-	-
46W	50°C	650mA	ON	-	-	ON	-	-
50W	50°C	700mA	ON	ON	-	-	-	-
50W	50°C	750mA	-	ON	ON	-	-	-
50W	45°C	850mA	ON	-	-	-	ON	-
50W	45°C	900mA	ON	ON	ON	-	-	-
50W	45°C	1050mA	ON	ON	ON	ON	-	-

注: 此附录与证书同时使用时有效。

威凯认证检测有限公司



中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722



# 中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2023181002043629

纸号: 070532

型号: MP 50 TCM拨码开关

输出功率	ta max	输出电流 /电压	拨码开关位置					
			6	5	4	3	2	1
25W	50°C	350mA	-	-	-	-	-	-
35W	50°C	500mA	ON	-	-	-	-	-
39W	50°C	550mA	-	ON	-	-	-	-
46W	50°C	650mA	ON	-	-	ON	-	-
50W	50°C	700mA	ON	ON	-	-	-	-
50W	50°C	750mA	-	ON	ON	-	-	-
50W	45°C	850mA	ON	-	-	-	ON	-
50W	45°C	900mA	ON	ON	ON	-	-	-
50W	45°C	1050mA	ON	ON	ON	ON	-	-

注: 铭牌上 $100^{\nabla}-110^{**}-127^{**}V\sim 50/60Hz I_{max}=0.42^{\nabla}-0.55^{**}A$   
特指UL认证出口适用的输入。

注: 此附录与证书同时使用时有效。

威凯认证检测有限公司



中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722