

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product	Electronic controlgear for LED modules
Name and address of the applicant	TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno (VA) Italy
Name and address of the manufacturer	TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno (VA) Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 TCI Telecomunicazioni Italia S.r.l. Via Parma 14 21047 Saronno (VA) Italy
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Input: 220-240 V, 50-60 Hz, I _{max} =0,18 A, λ= 0,96 Output: 250-1400 mA; V _{omax} =59 V; P _{omax} =30 W
Trademark (if any)	TCI or TN101
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	ATON (series)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This Certificate replaces Certificate No. NL-47060 dated 2017-05-30 in order to cover typing errors, update label, update Annex 7 for AU deviation. Refers to DEKRA CB report No.2102509.51 for list of models/types and electrical ratings.
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	2102509.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

