



中国国家强制性产品认证证书

证书编号: 2023181002042420

发证日期: 2023年05月25日

有效期至: 2028年05月24日

认证委托人名称及注册地址 TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) 意大利

生产者(制造商)名称及注册地址 TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) 意大利

生产企业名称及生产地址 TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) 意大利

产品名称和系列、型号、规格 LED 模块用交流电子控制装置 (LED 控制装置, 独立式, II 类, IP20, tc: 90°C, 恒流模式, SELV, 定温热保护: 110°C, 适宜直接安装在普通可燃材料表面)
见附件, 220-240V~, 50/60Hz

产品标准和技术要求 GB/T 17743-2021, GB 17625.1-2022, GB 19510.1-2009, GB 19510.14-2009

上述产品符合强制性产品认证实施规则 CNCA-C10-01: 2014 的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
经中国合格评定国家认可委员会认可 CNAS C146-P

本证书的相关信息可通过认监委网站 www.cnca.gov.cn 或扫描左下方二维码查询。



邓俊逸

威凯认证检测有限公司



中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722

068169



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2023181002042420

DATE OF ISSUE: May. 25, 2023

DATE OF EXPIRY: May. 24, 2028

NAME AND REGISTERED ADDRESS OF THE APPLICANT TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

NAME AND ADDRESS OF THE FACTORY TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

NAME, MODEL AND SPECIFICATION A. C. Supplied Electronic Controlgear For LED Modules (Independent SELV, tc: 90°C, Clas II,IP20, Suitable For Normally Flammable Surfaces ,Temperature Declared Thermally Protected:110°C)
See Appendix, 220-240V ~ , 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS GB/T 17743-2021,GB 17625.1-2022,
GB 19510.1-2009,GB 19510.14-2009

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C10-01: 2014).

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C146-P

This certificate can be verified through CNCA's website: www.cnca.gov.cn or the QR code at the lower left.



Dog Junyong



CVC Certification & Testing Co., Ltd.

No.3, Tiantaiyi Road, High-tech Industrial Development Zone, Science City, Guangzhou (510663) P. R. China

<http://www.cvc.org.cn>

Tel: +86-20-32293722

068169



中国国家强制性产品认证证书

附录:


第 1 页 共 2 页

证书编号: 2023181002042420

纸号: 068169

序号	产品型号	参数
1	DC MAXI JOLLY US cod. 151411	输出: Uout=90Vdc, 350-1050mA (恒流可调), 配套光源: Max. 60W LED 模块, ADIM 调光, PUSH L 调光
2	DC MAXI JOLLY US DALI cod. 151413	输出: Uout=90Vdc, 350-1050mA (恒流可调), 配套光源: Max. 60W LED 模块, DALI 调光, ADIM 调光, PUSH L 调光

输入: 220-240V~, 50/60Hz, Max. 0.29A, λ : 0.95 (Pout>30W), ta=-25...50/55°C (仅当输出功率为 40W,

输出电流 700mA 时, ta=55°C, 其他输出参数条件下, ta=50°C), tc=90°C, SELV, 定温热保护: 110°C, , 独立式, II 类

注: DC MAXI JOLLY US cod. 151411 拨码开关

输出功率	输出电流/电压	拨码开关位置					
		6	5	4	3	2	1
25W	350mA	-	-	-	-	-	-
35W	500mA	ON	-	-	-	-	-
39W	550mA	-	ON	-	-	-	-
46W	650mA	ON	-	-	ON	-	-
50W	700mA	ON	ON	-	-	-	-
54W	750mA	-	ON	ON	-	-	-
60W	850mA	ON	-	-	-	ON	-
60W	900mA	ON	ON	ON	-	-	-
60W	1000mA	ON	-	-	ON	ON	-
60W	1050mA	ON	ON	ON	ON	-	-

注: 此附录与证书同时使用时有效。

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2023181002042420

纸号: 068169

注: DC MAXI JOLLY US DALI cod.151413拨码开关

输出功率	输出电流/电压	拨码开关位置					
		6	5	4	3	2	1
25W	350mA	-	-	-	-	-	-
35W	500mA	ON	-	-	-	-	-
39W	550mA	-	ON	-	-	-	-
46W	650mA	ON	-	-	ON	-	-
50W	700mA	ON	ON	-	-	-	-
54W	750mA	-	ON	ON	-	-	-
60W	850mA	ON	-	-	-	ON	-
60W	900mA	ON	ON	ON	-	-	-
60W	1000mA	ON	-	-	ON	ON	-
60W	1050mA	ON	ON	ON	ON	-	-

注: 铭牌上 110**~127**V~特指 UL 认证出口适用的输入与额定最高环境温度。
170-276Vdc, 用于应急照明。

注: 此附录与证书同时使用时有效。

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722

