



# 中国国家强制性产品认证证书

证书编号: 2023181002041961

发证日期: 2023 年 05 月 11 日

有效期至: 2028 年 05 月 10 日

**认证委托人名称  
及注册地址** TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) 意大利

**生产者 (制造商)  
名称及注册地址** TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) 意大利

**生产企业名称  
及生产地址** TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) 意大利

**产品名称和系列、  
型号、规格** LED 模块用交流电子控制装置 (LED 控制装置, 内装式, 恒流模式, SELV, 定  
温热保护: 110°C, 适宜直接安装在普通可燃材料表面 )  
见附件, 220-240V~, 50/60Hz

**产品标准和  
技术要求** GB/T 17743-2021, GB 17625.1-2022, GB 19510.1-2009, GB 19510.14-2009

上述产品符合强制性产品认证实施规则 CNCA-C10-01: 2014 的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C146-P

本证书的相关信息可通过认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 或扫描左下方二维码查询。



邓俊逸

威凯认证检测有限公司



中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722

067301





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2023181002041961

DATE OF ISSUE: May. 11, 2023

DATE OF EXPIRY: May. 10, 2028

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) Italy

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) Italy

**NAME AND ADDRESS OF THE FACTORY** TCI Telecomunicazioni Italia S.r.l.  
Via Parma 14 21047 Saronno(VA) Italy

**NAME, MODEL AND SPECIFICATION** A. C. Supplied Electronic Controlgear For LED Modules ( Built-in, SELV, Suitable For Normally Flammable Surfaces ,Temperature Declared Thermally Protected:110°C)  
See Appendix, 220-240V~, 50/60Hz

**STANDARDS AND TECHNICAL REQUIREMENTS** GB/T 17743-2021,GB 17625.1-2022,  
GB 19510.1-2009,GB 19510.14-2009

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C10-01: 2014).

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C146-P

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn) or the QR code at the lower left.



*Dy Jonyang*



**CVC Certification & Testing Co., Ltd.**

No.3, Tiantaiyi Road, High-tech Industrial Development Zone, Science City, Guangzhou (510663) P. R. China

<http://www.cvc.org.cn>

Tel: +86-20-32293722

067301





# 中国国家强制性产品认证证书

附录:

第 1 页 共 4 页

证书编号: 2023181002041961

纸号: 067301

| 序号 | 产品型号           | 参数                                                                                                |
|----|----------------|---------------------------------------------------------------------------------------------------|
| 1  | PRO FLAT 40 BI | 输出: $U_{out}=59V_{dc}$ , 300-1050mA (恒流可调, 通过拨码开关调节),<br>配套光源: Max. 40W LED 模块, $t_c=90^{\circ}C$ |
| 2  | PRO FLAT 30 BI | 输出: $U_{out}=59V_{dc}$ , 350-725mA (恒流可调, 通过拨码开关调节),<br>配套光源: Max. 32W LED 模块, $t_c=85^{\circ}C$  |
| 3  | PRO FLAT 22 BI | 输出: $U_{out}=59V_{dc}$ , 125-500mA (恒流可调, 通过拨码开关调节),<br>配套光源: Max. 22W LED 模块, $t_c=75^{\circ}C$  |

注: 此附录与证书同时使用时有效。

邓俊尧

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722







# 中国国家强制性产品认证证书

附录：

第 2 页 共 4 页

证书编号：2023181002041961

纸号：067301

注：PRO FLAT 40 BI拨码开关

| 输出功率 | 输出电流   | 拨码开关位置 |    |    |    |
|------|--------|--------|----|----|----|
|      |        | 1      | 2  | 3  | 4  |
| 13W  | 300mA  | -      | -  | -  | -  |
| 15W  | 350mA  | -      | -  | -  | ON |
| 18W  | 400mA  | -      | -  | ON | -  |
| 20W  | 450mA  | -      | -  | ON | ON |
| 22W  | 500mA  | -      | ON | -  | -  |
| 24W  | 550mA  | -      | ON | -  | ON |
| 27W  | 600mA  | -      | ON | ON | -  |
| 29W  | 650mA  | -      | ON | ON | ON |
| 31W  | 700mA  | ON     | -  | -  | -  |
| 32W  | 750mA  | ON     | -  | -  | ON |
| 33W  | 800mA  | ON     | -  | ON | -  |
| 35W  | 850mA  | ON     | -  | ON | ON |
| 38W  | 900mA  | ON     | ON | -  | -  |
| 40W  | 950mA  | ON     | ON | -  | ON |
| 40W  | 1000mA | ON     | ON | ON | -  |
| 40W  | 1050mA | ON     | ON | ON | ON |

注：此附录与证书同时使用时有效。

邵俊尧

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话：+86-20-32293722







# 中国国家强制性产品认证证书

附录：

第 3 页 共 4 页

证书编号：2023181002041961

纸号：067301

PRO FLAT 30 BI拨码开关

| 输出功率 | 输出电流  | 拨码开关位置 |    |    |    |
|------|-------|--------|----|----|----|
|      |       | 1      | 2  | 3  | 4  |
| 15W  | 350mA | -      | -  | -  | -  |
| 16W  | 375mA | -      | -  | -  | ON |
| 17W  | 400mA | -      | -  | ON | -  |
| 18W  | 425mA | -      | -  | ON | ON |
| 19W  | 450mA | -      | ON | -  | -  |
| 21W  | 475mA | -      | ON | -  | ON |
| 22W  | 500mA | -      | ON | ON | -  |
| 23W  | 525mA | -      | ON | ON | ON |
| 24W  | 550mA | ON     | -  | -  | -  |
| 25W  | 575mA | ON     | -  | -  | ON |
| 26W  | 600mA | ON     | -  | ON | -  |
| 27W  | 625mA | ON     | -  | ON | ON |
| 28W  | 650mA | ON     | ON | -  | -  |
| 29W  | 675mA | ON     | ON | -  | ON |
| 30W  | 700mA | ON     | ON | ON | -  |
| 32W  | 725mA | ON     | ON | ON | ON |

注：此附录与证书同时使用时有效。

邓俊尧

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话：+86-20-32293722







# 中国国家强制性产品认证证书

附录:

第 4 页 共 4 页

证书编号: 2023181002041961

纸号: 067301

PRO FLAT 22 BI拨码开关

| 输出功率  | 输出电流  | 拨码开关位置 |    |    |    |
|-------|-------|--------|----|----|----|
|       |       | 1      | 2  | 3  | 4  |
| 5.5W  | 125mA | -      | -  | -  | -  |
| 6.5W  | 150mA | -      | -  | -  | ON |
| 7.5W  | 175mA | -      | -  | ON | -  |
| 8.5W  | 200mA | -      | -  | ON | ON |
| 9.5W  | 225mA | -      | ON | -  | -  |
| 11W   | 250mA | -      | ON | -  | ON |
| 12W   | 275mA | -      | ON | ON | -  |
| 13W   | 300mA | -      | ON | ON | ON |
| 14W   | 325mA | ON     | -  | -  | -  |
| 15W   | 350mA | ON     | -  | -  | ON |
| 16.5W | 375mA | ON     | -  | ON | -  |
| 17.5W | 400mA | ON     | -  | ON | ON |
| 18.5W | 425mA | ON     | ON | -  | -  |
| 19.5W | 450mA | ON     | ON | -  | ON |
| 21W   | 475mA | ON     | ON | ON | -  |
| 22W   | 500mA | ON     | ON | ON | ON |

注:

1. 输入: 220-240V~, 50/60Hz, SELV, , , 内装式;
2. 铭牌上 170-280V~, 用于应急照明。

注: 此附录与证书同时使用时有效。

邵俊尧

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话: +86-20-32293722

