



中国国家强制性产品认证证书

证书编号: 2019011002268080

委托人名称、地址

TCI Telecomunicazioni Italia S.r.l.

Via Parma 14 21047 Saronno (VA) 意大利

生产者(制造商)名称、地址

TCI Telecomunicazioni Italia S.r.l.

Via Parma 14 21047 Saronno (VA) 意大利

生产企业名称、地址

TCI Telecomunicazioni Italia S.r.l.

Via Parma 14 21047 Saronno (VA) 意大利

产品名称和系列、规格、型号

LED 模块用交流电子控制装置(LED 控制装置, 独立式, 恒流模式, 安全特低电压, $t_a: 45^{\circ}\text{C}$, $t_c: 75^{\circ}\text{C}$, I 类, IP20, 适宜直接安装在普通可燃材料表面, 定温热保护: 110°C , 控制端口调光)

见附件; 输入: 220-240V~, 50-60Hz

产品标准和技术要求

GB17625.1-2012; GB/T17743-2017; GB19510.1-2009; GB19510.14-2009

9

上述产品符合强制性产品认证实施规则 CNCA-C10-01:2014 的要求, 特发此证。

发证日期: 2020 年 01 月 07 日 有效期至: 2025 年 01 月 07 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询

经中国合格评定国家认可委员会认可 CNAS C001-P



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019011002268080

NAME AND ADDRESS OF THE APPLICANT

TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

NAME AND ADDRESS OF THE MANUFACTURER

TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

NAME AND ADDRESS OF THE FACTORY

TCI Telecomunicazioni Italia S.r.l.
Via Parma 14 21047 Saronno(VA) Italy

PRODUCT NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Independent, Constant Current Mode, SELV, ta:45°C, tc:75°C, Class I, IP20, Suitable For Direct Mounting On Normally Flammable Material, Temperature Declared Thermally Protected:110°C, Controlled Port Dimming)

See Appendix; Input: 220-240V~, 50-60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB17625.1-2012;GB/T17743-2017;GB19510.1-2009;GB19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C10-01:2014).

Valid from: Jan.07,2020

Valid until: Jan.07,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn
Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号：2019011002268080

纸 号：2539718

序号	产品型号	参数			
1	ATON 30/250-700 DALI	输出：Uout=59Vdc, 250-700mA（恒流可调）， 配套光源：Max. 30W LED 模块			
输入：220-240V~, 50-60Hz					
注：ATON 30/250-700 DALI 拨码开关					
输出电流	输出功率	拨码开关位置			
		4	3	2	1
250mA	13W	-	-	-	-
280mA	15W	ON	-	-	-
310mA	16.5W	-	ON	-	-
340mA	18W	ON	ON	-	-
370mA	19.5W	-	-	ON	-
400mA	21W	ON	-	ON	-
430mA	22.5W	-	ON	ON	-
460mA	24W	ON	ON	ON	-
490mA	26W	-	-	-	ON
520mA	27.5W	ON	-	-	ON
550mA	29W	-	ON	-	ON
580mA	30W	ON	ON	-	ON
610mA	30W	-	-	ON	ON
640mA	30W	ON	-	ON	ON
670mA	30W	-	ON	ON	ON
700mA	30W	ON	ON	ON	ON

注：此附录与证书同时使用时有效。



主 任：

陆 楠



中国质量认证中心